

---

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRPWFC20162083, Public Works Infrastructure Permit - Commercial

WATER UTILITIES FACILITY

Address: 1200 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
PW-ADA Inspection	Brice Lawson	Passed	Thursday, June 29, 2017

Informational

1 Brice Lawson 06/29/2017 2:41 PM

The ADA on the north side of the north driveway has been installed and the cross slope is under 2% and the running slope is under 8.33%.

The isolation joints need to be sealed. This is noted on the sidewalk inspection to have this completed.

**Comments:**

---