

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20171522, Building Permit - Commercial
Address: 2640 NE MCBAIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Failed	Thursday, June 29, 2017

Corrective Action Required

1	Misc	-FIREBLOCK COMBUSTIBLE WALL SPACE PER CODE -INSTALL #4 CU SUPPLY SIDE BONDING JUMPER FOR THE 200 AMP SEPARATELY DERIVED PANEL
---	------	---

Comments: