

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162935, Building Permit - Residential
Address: 1692 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, June 30, 2017

Corrective Action Required

1 Misc

****STREET SHALL BE CLEANED

-DECK: INSTALL HANDRAIL NO WIDER THAN 3.5".

**INSTALL GRASPABLE HANDRAIL

Comments: