

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161179, Building Permit - Commercial  
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Partial	Friday, June 30, 2017

Corrective Action Required

1	Misc	PVC PIPE PENETRATIONS OF RATED CEILING ASSEMBLIES TO BE PROTECTED AND FIRE-STOPPED PER APPROVED DRAWINGS.
---	------	---

Corrective Action Required

2	Misc	BUILDING EXTERIOR: - INSTALL PERMAMENT PARKING LOT LIGHT POLES - COMPLETE FINISH SITEWORK
---	------	---

Corrective Action Required

3	Misc	RESOLVE ISSUES PRESENTED BY: - FIRE DEPARTMENT - PLANNING DIVISION - PUBLIC WORKS
---	------	--

**Comments:**