

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Passed	Friday, June 30, 2017
Underslab Electrical Inspection - Commercial	John Borns	Passed	Friday, June 30, 2017
Underslab Plumbing Inspection - Commercial	John Borns	Passed	Friday, June 30, 2017

GREAT HALL S.O.G FLOOR CHanneled AND THE FOLLOWING PLACED TO BE COVERED BY POUR-BACK:
ONE 3/4" POLY GAS PIPE FROM C3.3/JJ TO C3.3/II
ONE 1/2" POLY GAS PIPE FROM C3.3/JJ TO C3.3/II.5
ONE 1-1/2" PVC CW PIPING FROM C3.3/JJ TO C3.3/II
ONE EACH 3/4" PVC ELECT CONDUITS FROM C3.3/JJ AND C3.3/II TO C3.3/II.5