



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

July 03, 2017

DBL ARCHITECTURE + INC
8031 WENONGA RD
LEAWOOD, KS 66206

Permit No: PRCOM20171395
Project Title: BEAUTY BAR MED SPA
Project Address: 110 SE 3RD ST, LEES SUMMIT, MO 64063
Parcel Number: 61230161300000000
Location: HOWARDS 1ST ADD TO L S E 22 1/2' OF LOT 12 & E 22 1/2' OF S 20' OF 11 BLK 17
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: TENANT FINISH FOR NEW MED SPA

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED: (verified at inspection)

Address shall be viewable from the roadway 3rd St.

2. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED: (verified at inspection)

Provide one 2A-10BC fire extinguisher to be mounted on a normal path of travel close to an exit.

Building Plan Review

Reviewed By: Joe Frogge

Approved with Conditions

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.
6/6/17 - Acknowledged in letter

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.