

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20171691, Building Permit - Residential  
Address: 4717 NE GATEWAY DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Suspended Slab Inspection</b>	Khanh Nguyen	Failed	Monday, July 03, 2017

### Corrective Action Required

1	Misc	-PROVIDE SUSPENDED GARAGE FLOOR STRUCTURAL PLAN ON SITE. REBAR LAYOUT SHALL BE PER PLAN -INSTALL I BEAM SUPPORT COLUMN AND BRACE FLOOR -INSTALL REBAR CHAIRS
---	------	---

### Comments: