

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20171691, Building Permit - Residential
Address: 4717 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Suspended Slab Inspection	Khanh Nguyen	Failed	Wednesday, July 05, 2017

Corrective Action Required

1	Misc	-PROVIDE SUSPENDED GARAGE FLOOR STRUCTURAL PLAN ON SITE. **PLACE REBARS IN THE CORRUGATIONS AND TIE TO PERPENDICULAR REBARS **PLACE 10 FT REBAR OVER I BEAM @ 8" OC W/ 1"-1.5" OF TOP CONCRETE COVER
---	------	--

Comments: