

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161179, Building Permit - Commercial
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Not Ready	Wednesday, July 05, 2017

Corrective Action Required

1 Misc

**PVC PIPE PENETRATIONS OF RATED CEILING ASSEMBLIES TO BE
PROTECTED AND FIRE-STOPPED PER APPROVED DRAWINGS.**

Corrective Action Required

2 Misc

BUILDING EXTERIOR:
- INSTALL PARKING LOT LIGHT POLES
- COMPLETE FINISH SITEWORK

Corrective Action Required

3 Misc

RESOLVE ISSUES PRESENTED BY:
- FIRE DEPARTMENT
- PLANNING DIVISION
- PUBLIC WORKS

Comments: