

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161750, Building Permit - Commercial  
Address: 783 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, July 05, 2017

Partial Correction  
1        Misc

OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X MOLD-TOUGH GWB RATED ASSEMBLIES AT STAIRWELLS:  
NORTH STAIRWELL:  
BASEMENT LEVEL 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT BACKSIDE JOIST BAYS  
FIRST FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT BACKSIDE JOIST BAYS;  
SECOND FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT BACKSIDE JOIST BAYS  
  
SOUTH STAIRWELL:  
FIRST FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT BACKSIDE JOIST BAYS;  
SECOND FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT BACKSIDE JOIST BAYS

Partial Correction  
2        Misc

OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X MOLD-TOUGH GWB RATED ASSEMBLIES AT ELEVATOR:  
2ND FLOOR: 1ST & 2ND LAYERS PRE-ROCK;

**Comments:**