

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161761, Building Permit - Commercial  
Address: 805 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, July 05, 2017

Partial Correction  
1 Misc

OK TO COVER COMPONENTS OF RATED ASSEMBLIES AT  
**STAIRWELLS:**

**SOUTH STAIRWELL:**

BASEMENT: 1ST & 2ND LAYER 5/8" TYPE X MOLD-TOUGH GWB  
INCLUDING PRE-ROCK BACKSIDE JOIST BAYS;

FIRST FLOOR 1ST LAYER @ WELL FACE + PRE-ROCK AT BACKSIDE  
JOIST BAYS; 2ND LAYER PRE-ROCK AT BACKSIDE JOIST BAYS;

**NORTH STAIRWELL:**

FIRST FLOOR 1ST LAYER @ WELL FACE + PRE-ROCK AT BACKSIDE  
JOIST BAYS; 2ND LAYER PRE-ROCK AT BACKSIDE JOIST BAYS;

Partial Correction  
2 Misc

RATED ASSEMBLIES AT **ELEVATOR SHAFT:**

**BASEMENT:** 1ST & 2ND LAYERS PRE-ROCK AT BACKSIDE JOIST  
BAYS

**FIRST FLOOR:** 1ST & 2ND LAYERS PRE-ROCK AT BACKSIDE JOIST  
BAYS

**Comments:**