

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160939, Building Permit - Commercial
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Partial	Wednesday, July 05, 2017

Corrective Action Required

1	Misc	ZONE A ALL-ROUGH-OK
		ZONE B ALL-ROUGH: -FIRECAULK GAP AROUND BATHROOM DAMPERS AT RATED CEILING MEMBRANE -ANCHOR SILL PLATE WITHIN 12" OF BREAKS; 2 ANCHORS PER SHORT PLATE -PROTECT PLUMBING WHERE WITHIN 1.5" OF NAILING SURFACE -PROTECT WIRING WHERE WITHIN 1.25" OF NAILING SURFACE

Comments: