

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20171833, Building Permit - Commercial
Address: 622 SW 3RD ST, Unit:M, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Passed	Thursday, July 06, 2017

Comments: A/G/V PIPING IN PLACE IN SAME TRENCH AS PREVIOUSLY-INSPECTED DWV PIPE. NO ISSUES FOUND. OK TO COVER WHEN READY AFTER SUCCESSFUL TESTING.