LEE'S SUMMIT

CODES ADMINISTRATION

Temporary Certificate of Occupancy

Permit #:	PRRES20163030
Address:	1699 NE PARKWOOD DR, LEES SUMMIT, MO 64064
Inspected On:	Thursday, July 06, 2017
Inspected By:	Khanh Nguyen
Expiration Date:	8/7/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Thursday, July 06, 2017

Corrective Action Required:

1	Misc	-OBTAIN LAWN IRRIGATION PERMIT
		-PERMIT DOES NOT SHOW FINISHED BASEMENT
		-FINAL GRADE, SOD, SPLASHBLOCKS
		-LOWER WATER METER TO FINAL GRADE. MAKE SURE THAT THE
		DISTANCE FROM TOP OF METER TO LID IS 14"-18"
		-SECURE AC WHIP WITHIN 12" OF DISCONNECT
		-COMPLETE DECK; NAIL ONE JOIST HANGER NEAR MIDDLE POST;
		INSTALL HANGERS UNDER TOP STAIR LANDING
		-INSTALL SECURITY STRIKE PLATE FOR DECK DOOR
		-INSTALL ANTI-BACKFLOW DEVICE FOR BASEMENT HOSE BIBB
		-INSTALL FACE PLATE FOR SUMP PUMP RECEPTACLE

***DO NOT USE THE DECK UNTIL THE DECK GUARDRAIL IS

COMPLETED