

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160277, Building Permit - Commercial  
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Thursday, July 06, 2017

Partial Correction

1	Misc	OK TO COVER WHEN READY TRENCHED PVC CONDUIT FOR BOLLARD LIGHTS AT: <b>N OF BLDG EAST OF N ENTRANCE SIDEWALK;</b>
---	------	---

<b>Sprinkler - Hydrostatic Test</b>	Michael Weissenbach	Passed	Thursday, July 06, 2017
-------------------------------------	---------------------	--------	-------------------------

**Comments:**