

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20171418, Building Permit - Commercial
Address: 2737 NE MCBAIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Thursday, July 06, 2017

Corrective Action Required
1 Misc

-RESTORE THE 1 HR STAIR ENCLOSURE WALL. FIRECAULK
PENETRATIONS; PATCH OPEN GAP; MUD SCREW HEADS

Comments: