

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20171228, Building Permit - Residential

Address: 617 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081619 NW LILAC PL, LEES SUMMIT, MO
64081615 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	John Borns	Passed	Thursday, July 06, 2017

Comments: OK TO POUR WHEN READY. INSURE MIN 3" COVERAGE ON ALL RE-BAR; SEE AT BOTTOM OF JUMPS. THREE UFER RE-BAR JUMPERS IN PLACE AT EAST WALL 2/3 TO N FROM SOUTH WALL.