

**CODES ADMINISTRATION**

**PLAN REVIEW CONDITIONS**

July 06, 2017

IRONWOOD CONSTRUCTION CO LLC  
31588 W 271ST ST  
PAOLA, KS 66071

Permit No: PRCOM20171258  
Project Title: B&J PEERLESS ADDITION  
Project Address: 2301 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064  
Parcel Number: 52240040400000000  
Location: REPLAT NO 1 OF LAKEWOOD BUS CENTER ON I-470 PLAT J LOT 43A2  
Type of Work: ADDITION COMMERCIAL  
Occupancy Group:  
Description: BUILDING ADDITION INTENDED FOR STORAGE

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

**Fire Plan Review**

**Reviewed By: Jim Eden**

**Approved with Conditions**

1. Hose connections

ACTION REQUIRED:

3206.8 Fire department hose connections.

Where exit passageways are required by the International Building Code for egress, a Class I standpipe system shall be provided in accordance with Section 905.

2. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

ACTION REQUIRED: (Information purposes)

Have the fire alarm system contractor provide shop drawings for the fire alarm system modifications to be done.

3. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED: (information purposes)

Field tests and acceptance testing will be required for the fire alarm and fire sprinkler systems prior to the final occupancy inspection. to schedule a test contact the fire department at 816-969-1300

4. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

ACTION REQUIRED: (verified at inspection)

The existing fire sprinkler system shall be current with all required service and maintenance. A current service tag shall be posted on the systems riser.

5. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

ACTION REQUIRED: (information purposes)

Have the fire sprinkler system contractor provide shop drawings of the fire sprinkler system modification to be done.

6. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED: (verified at inspection)

Provide a minimum of (rated 5 pound) two 2A-10BC fire extinguishers. The fire extinguishers shall be mounted on a normal path of travel close to an exit. Travel distance to an extinguisher shall be a maximum of 75 feet.

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Approved with Conditions**

3. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informaional purposes.

**Licensed Contractors**

**Reviewed By: Joe Frogge**

**Approved**

- Approved to issue per the listed conditions.
- Do not issue per the listed conditions.
- Approved to construct foundation only per the listed conditions.
- Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

\_\_\_\_\_  
Signature of Applicant

\_\_\_\_\_  
Date

\_\_\_\_\_  
Print Applicant Name

\_\_\_\_\_  
CompanyName

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***