

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170753, Building Permit - Residential
Address: 1336 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Thursday, July 06, 2017

Corrective Action Required

1	Misc	-INSTALL ALL EXTERIOR DOOR FRAMES PER LS SECURITY CODE. **NOT DONE AT THIS TIME. MAKE SURE THAT ANY GAP BETWEEN THE DOOR FRAME AND STUD AT HINGES AND STRIKE PLATE SIDE IS FILLED WITH SOLID WOOD PER LS SECURITY CODE -COMPLETE FRAMING, INSTALL FIREPLACE, AND GAS CONNECTION AND FIREBLOCK AS REQUIRED **FB THE FIREPLACE SPACE FROM FURDOWN&JOIST SPACE
---	------	--

***OK TO INSULATE

Comments: