

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Friday, July 07, 2017

Partial Correction
2 Misc

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES:

A101C; A118; A119; A153C; A153D; A161; A163;

A201 & CORR; A202-205; A207A; A209; A210; A212-216; A220-222; A250-252; A278;

RESTROOMS 102 & 103

C101; C102; C102A; C103; C103A; C104; C105; C106; C150; C151; 151A; 151B; C152; C154; C155; C155A; C155B; STAIR 156; C156A; C157B; C159;

C202; 203; 204A; 204B; 205; 205B-222; C224; C225; C250A; C252;-257; C260-270; C272-274; C277;

[2-156; 2-157; 2-158; 2-159; 2-160; 2-161;

2-201; 2-257; 2-257A; 2-257B; 2-258; 2-259; 2-260; 2-261(D);
[2-202; 2-203; 2-204; 2-205; 2-206; 2-250; 2-252; 2-253;

[3-153; 3-153A; 3-153B; 3-156B; 3-156C;

[4-158;

4-201; 4-202; 4-203; 4-255; 4-258; 4-259; 4-260; 4-262; 4-263;
4-264; **4-256;**

Underground Electrical Inspection - Commercial

John Borns

Partial

Friday, July 07, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY TRENCHED PVC CONDUIT FOR BOLLARD LIGHTS AT:
N OF BLDG EAST OF N ENTRANCE SIDEWALK;
S OF BLDG ALONG EDGE OF E-W SIDEWALK FROM E END TO ONE BOLLARD W OF ENTRANCE SIDEWALK;

Underground Electrical Inspection - Commercial

John Borns

Partial

Friday, July 07, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY TRENCHED PVC CONDUIT FOR BOLLARD LIGHTS AT:
N OF BLDG EAST OF N ENTRANCE SIDEWALK; **S OF BLDG ALONG EDGE OF E-W SIDEWALK COMPLETE FROM E END TO W END;**

Comments: