

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20171326, Building Permit - Residential
Address: 1828 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|--|--------------|-----------|-----------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Gas Piping Inspection - Residential | Mark Harding | Not Ready | Monday, July 10, 2017 |

Corrective Action Required

| | | |
|---|------|--|
| 1 | Misc | lack of erosion control and gravel in the street. support wardflex at furnace firepalce not installed wardflex isn't bonded |
|---|------|--|

Comments: