

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit: PRRES20170161, Building Permit - Residential  
Address: 1695 NE PARKWOOD DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Bart Reese	Passed	Monday, July 10, 2017
<b>Sidewalk Inspection</b>	Bart Reese	Passed	Monday, July 10, 2017

**Comments: Concrete was not set up yet. Sidewalk must meet ADA requirements: must be <2% cross-gradient.**