

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Not Ready	Tuesday, July 11, 2017
Partial Correction 1 Misc		OK TO COVER WHEN READY GWB CEILING / SOFFIT FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: C119; C121; C122; C123; C148; C158; [C104; C105; C108; C115; C118; [C102; C104 - C108; C113 - C129; C131 - C134; C137 - C138; C140; C142 - C144; C146; C147 - C149; C154 - C159; C163; FOUR CLOUD CEILINGS AT AEROBICS 157;	
Rated Assembly Inspection	John Borns	Partial	Tuesday, July 11, 2017
Partial Correction 1 Misc		OK TO COVER WHEN READY COMPONENTS OF RATED WALL ASSEMBLIES: 104; 105; 106; 107; 108; 109; 110; 113; 117; 118; 119; 122; 127; 128; 135-138; 142; 143; 145; 147; 148; 157; 158; [154;	
Partial Correction 2 Misc		OK TO TAPE, MUD, & FIRE-STOP WHEN UL P522 RATED CEILING ASSEMBLIES AT SPACES: 104-108; 110; 113; 115; 117; 118; 121-123; 125-129; 132; 135; 136-138; 141- 144; 147; 148; 154-158; 159; 161; 162;	
Partial Correction 3 Misc		PP1 WALLS: SHAFT LINER LAYER APPROVED; OK TO APPLY 5/8" TYPE X AT OPPOSITE FACE AT C113 WEST & C157 EAST;	

Comments:

