



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20171522 Date: July 11, 2017
Project Title: FCI FEDERAL Applicant:
Location:
2640 NE MCBAINE DR, LEES SUMMIT, MO 64064
Type of Work:
Occupancy Group:
Description: TENANT FINISH FOR WATCHMEN SECURITY SERVICES LLC
DOCUMENT STORAGE FACILITY 10312 E 63RD TERRACE
Construction Type: Type VB (Unprotected) RAYTOWN, MO 64133
Map Page: 175R Primary: (816) 744-8900

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Acceptance testing of the system will be required prior to the final occupancy inspection. To schedule testing contact the fire department at 816-969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.