

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161937, Building Permit - Commercial
Address: 801 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Tuesday, July 11, 2017

Partial Correction
1 Misc

EXTERIOR SHEATHING OK TO COVER WHEN READY.

- CHECK DOOR HEADER BEARING ON JACK STUDS; SHIM ALL GAPS.
- COMPLETE/CORRECT SILL PLATE ANCHORAGE; SEE PAINT-MARKED LOCATIONS.
- COMPLETE NAILING OF INTERIOR SHEATHING; SEE - PAINT MARKED LOCATIONS.

Comments: