

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161938, Building Permit - Commercial  
Address: 813 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Partial	Tuesday, July 11, 2017

Partial Correction

1      Misc

EXTERIOR SHEATHING OK TO COVER WHEN READY.  
- CHECK DOOR HEADER BEARING ON JACK STUDS; SHIM ALL GAPS.  
- COMPLETE/CORRECT SILL PLATE ANCHORAGE; SEE PAINT-MARKED LOCATIONS.  
COMPLETE NAILING OF INTERIOR SHEATHING; SEE - PAINT MARKED LOCATIONS.

**Comments:**