

FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

July 12, 2017

SULLIVAN PALMER ARCHITECTS 8849 LONG LENEXA, KS 66215

Permit No:	PRCOM20171431
Project Title:	LION PETROLEUM
Project Address:	3325 SW 3RD ST, LEES SUMMIT, MO 64081
Parcel Number:	6242098140000000
Location:	NEW LONGVIEW COMMERCIAL DISTRICT THIRD PLAT LOTS 42 43 51-54 TRACTS
	C D & ELOT 42
Type of Work:	ALTERATION COMMERCIAL
Occupancy Group:	MERCANTILE
Description:	KITCHEN REMODEL INCLUDING NEW GREASE HOOD

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

 Ansul extinguishing system ACTION REQUIRED:
Provide manufacturers specs on the pre-engineered ansul system to be installed.

2. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Acceptance testing of the type1 hood and the ansul system will be required prior to the final occupancy inspection. To schedule testing contact the fire department at 816-969-1300.

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. For the Health Department review contact Deb Sees with the Jackson County Public Works Department, Environmental Services Division, at (816) 847-7070. Health Department approval is required prior to receiving any type of building permit from the City of Lee's Summit.

Action required: Comment is for informational purposes. 7/11/17 - acknowledged in letter

2. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is for informational purposes. 7/11/17 - acknowledged in letter

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.