

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20172013, Building Permit - Residential
Address: 2232 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Deck Final Inspection - Residential	Dale Carter	Failed	Thursday, July 13, 2017

Corrective Action Required

1	Misc	New posts installed and are notched to take care of beam overspan issue; however, new posts have not been anchored to piers to resist lateral and uplift forces.
---	------	--

Comments: