

July 12, 2017

Joe Frogge
Plans Examiner
Codes Administration Department
220 SE Green Street
Lee's Summit, MO 64063

Project: **Verizon TI**

Permit No: **PRCOM20170985**

Location: **1706 Chipman Rd.
Lee's Summit, MO 64081**

To the Construction Documents for the above named project:

The Construction Documents are modified, supplemented, or augmented as follows. The existing corridor wall at the rear of the tenant space is a 2 hour rated wall assembly. The building is fully sprinklered. All other wall assemblies within the tenant space and that separate the tenant space from adjacent tenant spaces are not required to have a fire resistance rating. Please disregard any indication for any walls other than the rear corridor wall to achieve a fire-resistance rating.

Sincerely,

KENNETH VAN TINE
AIA, LEED AP

