

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20170989, Building Permit - Residential  
Address: 1691 NE PARKWOOD DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Partial	Thursday, July 13, 2017

Corrective Action Required

1	Misc	-WINDOW SIZE ALONG THE REAR BRACE WALL LINES (BOTH MAIN FLOOR AND BASEMENT) ARE NOT PER PLAN. HAVE ARCHITECT ADDRESS BRACE WALL COMPLIANCE PER IRC 602.10.2&3
---	------	---

\*\*\*OK TO ROCK IF THE ARCHITECT OK THE ABOVE

**Comments:**