

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

July 14, 2017

CITY GIRLS BEAUTY SALON 1229 SW NAGONA LN LEES SUMMIT, MO 64082

Permit No: PRCOM20172321

Project Title: CITY GIRLS BEAUTY SALON

Project Address: 300 SW NOEL ST, Unit:A, LEES SUMMIT, MO 64063

Parcel Number: 61420011200000000

Location: SHAMROCK ADD RES (LS) LOT 4

Type of Work: CHANGE OF TENANT

Occupancy Group: BUSINESS

Description: TENANT FINISH FOR HAIR SALON

(CHANGE OF USE ONLY - NO CONSTRUCTION)

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200 Fire Department (816) 969-1300

Licensed Contractors Reviewed By: Joe Frogge Approved

Building Plan Review Reviewed By: Joe Frogge Approved with Conditions

1. Approval of drawings contingent upon their being no construction. Per applicant, the only work done was replacing dog wash sinks with hair wash sinks.

Fire Plan Review Reviewed By: Joe Dir Approved with Conditions

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:(verified at inspection)

Post the suite designation on the exterior of all doors leadinf into the business. Address shall be readable from the roadway.

2. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED: (verified at inspection)

Provide a minimum of one 2A-10BC fire extinguisher to be mounted close to an exit.

^{*}drawing is in plan review file

ACTION REQUIRED: No keyed locks on the egress side of	an exit.
[B] 1008.1.9 Door operations.	oors shall be readily openable from the egress side without the use of
a key or special knowledge or effort.	ors shall be readily openable from the egress side without the use of
<u>x</u> Approved to issue per the listed conditions.	
Do not issue per the listed conditions.	
Approved to construct foundation only per th	e listed conditions
Requires Final Development Plan approval prior to issuing this building permit.	
Requires Final Development Plan approval prior to issuing this building permit.	
The applicant agrees to incorporate the aforementioned	I requirements into the project to conform to applicable City Codes
and Ordinances.	requirements into the project to comorni to applicable city codes
and Ordinances.	
Signature of Applicant	Date
Signature of Apprount	
Print Applicant Name	CompanyName
Time Applicante Hame	company italic
The approval of plans and specifications does not	permit the violation of any section of the Building Codes or
other City Ordinances or State Law.	
other city oraniances of State Law.	

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as

a structural review of the project.