

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161178, Building Permit - Commercial  
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Friday, July 14, 2017

Partial Correction  
1 Misc

OK TO COVER WHEN READY GWB CEILING / SOFFIT FRAMING +  
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: C102; C104 -  
C108; C115; C118; C119; C121 - C129; C131 - C134; C137 - C138;  
C140; C142 - C144; C146 - C149; C154 - C159; FOUR CLOUD  
CEILINGS AT AEROBICS 157; C163; **[104; 106; 107;**

**Comments:**