

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161750, Building Permit - Commercial
Address: 783 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, July 14, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X
MOLD-TOUGH GWB RATED ASSEMBLIES AT STAIRWELLS:
NORTH STAIRWELL:
BASEMENT LEVEL 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK
AT JOIST BAYS

FIRST FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT
JOIST BAYS;

SECOND FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT
JOIST BAYS

THIRD FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST
BAYS

SOUTH STAIRWELL:
FIRST FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT
JOIST BAYS;

SECOND FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT
JOIST BAYS

THIRD FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST
BAYS

Partial Correction
2 Misc

OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X

MOLD-TOUGH GWB RATED ASSEMBLIES AT ELEVATOR:
2ND FLOOR: 1ST & 2ND LAYERS PRE-ROCK;
3RD FLOOR: 1ST LAYER PRE-ROCK;

Comments: