

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20172030, Building Permit - Residential
Address: 4056 NE CHAPEL MANOR DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|--|--------------|----------|-----------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Underslab Plumbing Inspection - Residential | Khanh Nguyen | Passed | Monday, July 17, 2017 |

Comments: