

Inspection Summary

Permit #: PRRES20170130, Building Permit - Residential
Address: 404 SE WEISS CIR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Partial	Tuesday, July 18, 2017

Partial Correction
1 Misc

3. Rear grade, required to have minimum 6" clearance from grade, will check at final.

Comments: