

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161177, Building Permit - Commercial  
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Tuesday, July 18, 2017
Partial Correction 1       Misc		OK TO COVER WHEN READY 5/8" TYPE X GWB AT UNIT FACE OF STAIRWELL WALLS AT: 214; 314 GWB ABOVE CEILING ONLY	
Partial Correction 2       Misc		OK TO COVER WHEN READY RATED ASSEMBLIES AT INTERIOR WALLS AT STAIRWELLS:  FRAMING + SHAFT LINER BOARD -- WELL FACE + UNIT SIDE AT: 102; 202; 203; 213; 302; 303; 313; 314;  WEST STAIRWELL: FRAMING + SHAFT LINER BOARD INCLUDING CLIPS AND FIRE-BLOCKING -- <b>WELL FACE + OPPOSITE FACE AT 4TH FLOOR</b>  <b>SE STAIRWELL: 5/8" TYPE X GWB AT STAIRWELL FACE WEST WALL ABOVE LID AT 4TH FLR;</b>   5/8" TYPE X GWB AT BACK FACE AT: WALLS ABOVE 4TH FLR CEILING AT ATTIC;	
Partial Correction 3       Misc		OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB CEILINGS AND WALLS AT:  CEILING ONLY AT 201;	

204; 205; 206; 207; 208; 209; 211; 212; 214; 215; CORR 216; 217;  
CORR 219; 221; 222; 223; 224;

CORR 301/316/325; 304; 305; 306; 307; 308; 309; 310; 311; 312;  
314; 315; 317; 322; 323; 324;

[4TH FLOOR CORRIDOR COMPLETE + ALL UNITS/ROOMS  
**INCLUDING 408**

**Comments:**