

Temporary Certificate of Occupancy

Permit #: PRRES20161966
Address: 312 SE MILL CREEK DR, LEES SUMMIT, MO 64063
Inspected On: Wednesday, July 19, 2017
Inspected By: Dale Carter
Expiration Date: 8/21/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Dale Carter	Temporary C of O	Wednesday, July 19, 2017

Corrective Action Required:

1 Misc Final grade not correct at rear of property. Slope should be continuous from the rear of the house to the rear of the property. Currently, a ridge is present that will trap water on the patio.