

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170703, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Wednesday, July 19, 2017

Partial Correction

1	Misc	RETAINING WALL FOOTING PER SECTIONS (2), (3) AND (4) ON SHEET S1.0 OK TO POUR WHEN READY AND APPROVED BY 3RD PARTY INSPECTOR
---	------	--

Partial Correction

2	Misc	<p>OK TO POUR WHEN READY SECTIONS OF CONCRETE TIE BEAM, GRADE BEAM + INTEGRAL PIER CAPS AS FOLLOWS:</p> <p>"PANT-LEG" TIE BEAM TRIANGLE BETWEEN (12.1) AND (13)</p> <p>ON (J) FROM (13.5) TO (14.7); FROM (14.7) TO (17.5); [FROM (12) TO (13.7)]</p> <p>ON (G) FROM (13) TO (16); [FROM (12.8) TO (13.3)]</p> <p>[ON (13) FROM (E') TO (J)]</p> <p>ON (14) FROM (J) TO (I); FROM (E'.2) TO (F'.8); FROM (G.2) TO (I);</p> <p>ON (17) FROM (E'.2) TO (G.8); FROM (H.2) TO (H.4);</p> <p>ON (15) FROM (E'.2) TO (G.8); FROM (H.2) TO (H.4);</p> <p>ON (16) FROM (E'.2) TO (H.5);</p> <p>H/16.7 TO G/16; /17 TO H/16; H/16.7 TO H/18.2;</p> <p>18.2/E' TO 18./I TO 17.8/I TO 17.8/I.7;</p>
---	------	---

Comments: