

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Not Ready	Thursday, July 20, 2017

Partial Correction

1	Misc	OK TO COVER WHEN READY GWB CEILING / SOFFIT FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: C102; C104 - C108; C115; C118; C119; C121 - C129; C131 - C134; C137 - C138; C140; C142 - C144; C146 - C149; C154 - C159; FOUR CLOUD CEILINGS AT AEROBICS 157; C163; [104; 106; 107;
---	------	---

Corrective Action Required

2	Misc	COURTESY PRELIMINARY OBSERVATIONS AT SPACES WITH NO CEILING FRAMING/GRID INSTALLED TO DATE: 119; 121 - 124; NOTE: SECURE FLEX INSULATION AT COLLARS AND JOINTS PER SMACNA & AIR DIFFUSION COUNCIL
---	------	--

Comments: