

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20170199, Building Permit - Residential

Address: 2203 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822205 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822207 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822201 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Dale Carter	Failed	Thursday, July 20, 2017

### Corrective Action Required

1 Misc

#### ALL UNITS:

- Final grade, sod, splashblocks, etc.
- Hammer-arrestors on laundry connections.
- Tighten electric recept. yokes.
- Seal exterior penetrations (line-sets, coax, etc.)

#### UNIT 2203:

- Install / Expose laundry water connections.

#### UNIT 2205:

- Connect dishwasher drain hose.

#### UNIT 2207:

- Patch drywall in garage ceiling.

**Comments:**