

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20171075, Building Permit - Commercial
Address: 1155 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Passed	Friday, July 21, 2017

Comments: REMOVE ANY ABANDONED MATERIAL. SUPPORT AND SECURE LOW-VOLTAGE CABLE AS WELL AS POSSIBLE AND CLOSE L.V. BOXES. OK TO COVER WHEN READY.