

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, July 21, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY RATED ASSEMBLIES AT
INTERIOR WALLS AT STAIRWELLS:

FRAMING + SHAFT LINER BOARD -- WELL FACE + UNIT SIDE AT:
102; 202; 203; 213; 302; 303; 313; 314;

WEST STAIRWELL:
FRAMING + SHAFT LINER BOARD INCLUDING CLIPS AND
FIRE-BLOCKING -- WELL FACE + OPPOSITE FACE AT 3RD FLOOR
(303); AT 4TH FLOOR (402) WELL FACE GWB COMPLETE TO ROOF;
OPPOSITE FACE AT 2ND FLR (203) OK FOR 5/8" TYPE X;

SE STAIRWELL: 5/8" TYPE X GWB AT STAIRWELL FACE WEST
WALL ABOVE LID AT 4TH FLR;

5/8" TYPE X GWB AT BACK FACE AT: WALLS ABOVE 4TH FLR
CEILING AT ATTIC;

Partial Correction
2 Misc

OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB CEILINGS
AND WALLS AT:

CEILING ONLY AT 201;

204; 205; 206; 207; 208; 209; 211; 212; 214; 215; CORR 216; 217;
CORR 219 INCLUDING SOFFIT TO ENCLOSE ELECT CABLES; 221;

222; 223; 224;

CORR 301/316/325; 304; 305; 306; 307; 308; 309; 310; 311; 312;
314; 315; 317; 322; 323; 324;

4TH FLOOR CORRIDOR COMPLETE + ALL UNITS/ROOMS
INCLUDING 408

Partial Correction
3 Misc

DUCT CHASE AT 303 SW CORNER:
TWO LAYERS 5/8" TYOE X GWB AT CORRIDOR WALL -- OK TO
TAPE & MUD, THEN TO INSTALL DUCT, THEN TO INSTALL PART OF
SHAFT LINER ENCLOSURE, LEAVING OPENING FOR INSPECTION
BEFORE COMPLETELY CLOSING CHASE.

DUCT CHASE AT 306 SW CORNER:
SIMILAR TO 303 ABOVE.

Comments: