

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160939, Building Permit - Commercial
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Friday, July 21, 2017
Partial Correction 1 Misc		RATED CEILING ASSY OK BELOW: -ZONE A-OK -ZONE C-OK -ZONE B: ALL AREAS EXCEPT HEARTH&GATHERING&KITCHEN-2ND LAYER OK -ZONE A&C: ALL 1HR SMOKE BARRIERS WALL FROM FLOOR TO ROOF DECK-OK	
Hood/Duct Inspection	Khanh Nguyen	Partial	Friday, July 21, 2017
Partial Correction 1 Misc		-LIGHT TESTED LONG SECTION ON GROUND-OK. THE HOOD-TO-GREASE DUCT TRANSITION GD AND THE ABOVE GD WILL BE TESTED AGAIN WHEN ALL ARE WELD TOGETHER.	
In-wall Inspection	Khanh Nguyen	Passed	Friday, July 21, 2017

Comments: