

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20171833, Building Permit - Commercial
Address: 622 SW 3RD ST, Unit:M, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Not Ready	Monday, July 24, 2017

Partial Correction
1 Misc

NO ISSUES FOUND ON IN-WALL PLUMBING IN PLACE TO DATE.

**CALL FOR COMPREHENSIVE IN-WALL INSPECTION WHEN ALL
TRADES ARE COMPLETE AND READY FOR INSPECTION.**

Comments: