

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20161381, Building Permit - Residential
Address: 3123 SE 3RD TER, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Dale Carter	Failed	Tuesday, July 25, 2017

Corrective Action Required

2	Misc	<ol style="list-style-type: none">1. Final grade, sod, splash blocks, etc.2. Protect I-joists in basement.3. Repair jacuzzi tub - currently can only be turned on/off by tripping/resetting the GFI receptacle near the water closet.4. Security screws at rear door.5. Guardrails needed at front porch: at west side, and at west end of north side.
---	------	--

Comments: