

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20171418, Building Permit - Commercial
Address: 2737 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Tuesday, July 25, 2017

Corrective Action Required

1	Misc	-THE RESTROOM DOORS LOCK LEVEL ARE NOT ACCESSIBILITY-COMPLIANT
---	------	---

Occupancy Inspection - Fire	Michael Weissenbach	Passed	Tuesday, July 25, 2017
--	------------------------	--------	------------------------

Alarm Test	Michael Weissenbach	Passed	Tuesday, July 25, 2017
-------------------	------------------------	--------	------------------------

Comments: