

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20160277  
**Address:** 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086  
**Inspected On:** Tuesday, July 25, 2017  
**Inspected By:** John Borns Michael Weissenbach Christina Stanton Michael Weissenbach  
**Expiration Date:** 9/28/2017 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Tuesday, July 25, 2017

Corrective Action Required:

3 Misc ROOFTOP:  
- COMPLETE LIGHTNING PROTECTION SYSTEM  
- SECURE A/C WHIP TO WALL  
- FINAL CLEANUP

Corrective Action Required:

2 Misc RESOLVE FIRE DEPARTMENT ISSUES

Corrective Action Required:

1 Misc COMPLETE FINISH SITEWORK  
- RESOLVE ANY PUBLIC WORKS ISSUES  
- RESOLVE ANY PLANNING ISSUES

Corrective Action Required:

4 Misc COMPLETE WORK READY FOR FINAL INSPECTION IN:  
AREAS 1-B AND 1-D.

BE ADVISED IF FURNITURE INSTALLATION IS PERFORMED PRESENTLY IN THESE AREAS INSTALLERS ARE AT RISK DUE TO CONTINUING CONSTRUCTION ACTIVITY. GENERAL CONTRACTOR TO ENSURE INSTALLER SAFETY.

<b>Occupancy Inspection - Fire</b>	Michael Weissenbach	Temporary C of O	Tuesday, July 25, 2017
------------------------------------	---------------------	------------------	------------------------

<b>Occupancy Inspection - Planning</b>	Christina Stanton	Temporary C of O	Tuesday, July 25, 2017
--	-------------------	------------------	------------------------

Corrective Action Required:

1	Install all landscaping materials per approved landscape plan.
---	--

<b>Alarm Test</b>	Michael Weissenbach	Passed	Tuesday, July 25, 2017
-------------------	---------------------	--------	------------------------