

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161177, Building Permit - Commercial  
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, July 26, 2017

Partial Correction  
1 Misc

OK TO COVER WHEN READY RATED ASSEMBLIES AT STAIRWELLS:

FRAMING + SHAFT LINER BOARD -- WELL FACE + UNIT SIDE AT:  
102; 202; 203; 213; 302; 303; 313; 314;

WEST STAIRWELL:  
FRAMING + SHAFT LINER BOARD INCLUDING CLIPS AND  
FIRE-BLOCKING -- WELL FACE + OPPOSITE FACE AT 3RD FLOOR  
(303); AT 4TH FLOOR (402) WELL FACE GWB COMPLETE TO ROOF;  
OPPOSITE FACE AT 2ND FLR (203) OK FOR 5/8" TYPE X; **[5/8" TYPE  
X OK TO TAPE, MUD AND FIRE-STOP AT 402 UP TO ROOF;  
OPPOSITE FACE AT 403 OK TO HANG 5/8" TYPE X;**

SE STAIRWELL: 5/8" TYPE X GWB AT STAIRWELL FACE WEST  
WALL ABOVE LID AT 4TH FLR;

5/8" TYPE X GWB AT BACK FACE AT: WALLS ABOVE 4TH FLR  
CEILING AT ATTIC;

Partial Correction  
3 Misc

DUCT CHASE AT 303 SW CORNER:  
TWO LAYERS 5/8" TYOE X GWB AT CORRIDOR WALL -- OK TO  
TAPE & MUD, THEN TO INSTALL DUCT, THEN TO INSTALL PART OF  
SHAFT LINER ENCLOSURE, LEAVING OPENING FOR INSPECTION  
BEFORE COMPLETELY CLOSING CHASE.

DUCT CHASE AT 306 SW CORNER:  
SIMILAR TO 303 ABOVE.

**Comments:**