

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160939, Building Permit - Commercial  
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Khanh Nguyen	Partial	Wednesday, July 26, 2017

Corrective Action Required

1	Misc	IN-WALL ROUGHINGS: -ZONE A, B, AND C-OK
---	------	--

<b>Rated Assembly Inspection</b>	Khanh Nguyen	Partial	Wednesday, July 26, 2017
----------------------------------	--------------	---------	--------------------------

Partial Correction

1	Misc	<p>RATED CEILING ASSY OK BELOW: -ZONE A-OK -ZONE C-OK -ZONE B: ALL AREAS EXCEPT HEARTH&amp;GATHERING</p> <p>SMOKE BARRIERS WALL: -ZONE A&amp;C: ALL SB WALL FROM CEILING TO ROOF DECK-OK</p> <p>CORRIDOR SMOKE PARTITION WALL: -ZONE C-OK</p>
---	------	---

**Comments:**