



**LEE'S SUMMIT**  
MISSOURI



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No: PRCOM20171522 Date: July 26, 2017  
Project Title: FCI FEDERAL Applicant:  
Location: 2640 NE MCBAIN DR, LEES NORTHWEST MO AUTOMATIC SPRINKLER  
SUMMIT, MO 64064 SE 7401 HIGHWAY 69  
LAWSON, MO 64062  
Type of Work:  
Occupancy Group:  
Description: TENANT FINISH FOR Primary: (816) 580-4072  
DOCUMENT STORAGE  
FACILITY  
Construction Type: Type VB (Unprotected)  
Map Page: 175R

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

**ACTION REQUIRED:**

Field tests and final acceptance testing will be required for the system prior to the final occupancy inspection. to schedule a test contact the fire department at 816-969-1300.

**2. ACTION REQUIRED:**

If a ceiling is constructed for the riser room a sprinkler head will be required to be installed.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**